



## Filing Receipt

**Received - 2022-01-14 11:18:31 AM**  
**Control Number - 52667**  
**ItemNumber - 52**

Cherokee County Electric Cooperative Association's  
House Bill 4150 Compliance Report

January 4, 2022


Public Utility Commission  
Central Records Filing Clerk  
P.O. Box 13326  
Austin, TX 78711-3326

RE: Project 52667 Filings of Attestations Demonstrating Compliance with HB 4150

Dear Sir or Madam:

Enclosed is the report for Cherokee County Electric Cooperative Association demonstrating compliance with HB 4150 and accompanying affidavit attesting to the validity of our report.

Sincerely,

A handwritten signature in black ink, appearing to be 'Bart Bauer', with a stylized, flowing script.

Bart Bauer  
Manager of Engineering

Enclosure

## Cherokee County Electric Cooperative Association's House Bill 4150 Compliance Report

Cherokee Country Electric Cooperative Association, ("CCECA") hereby files this Report regarding compliance with House Bill 4150 ("HB 4150")

- A Declaration that each distribution line above 1 kilovolt or transmission line above 60 kilovolts owned by the utility that crosses a lake listed in PURA 38.004(b) meets the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2)
- The date on which the company verified each line's compliance with the applicable NESC Standard

Cherokee County Electric Cooperative Association, ("Cooperative") owns and operates distribution lines above 1 kilovolt that cross Lake Palestine and Lake Tyler, lakes listed in PURA Section 38.004(b). Except as listed below. The distribution lines crossing Lake Palestine and Lake Tyler were found to be in compliance on May 4<sup>th</sup>, 2021, with Rule 232 of the NESC in effect as of September 1, 2019.

Provided below is a list of the distribution lines crossing Lake Palestine and Lake Tyler that had portions of the lines which were not in compliance with Rule 232 of the NESC in effect as of September 1, 2019.

The Cooperative does not own or operate any transmission lines above 60 kilovolts that crosses any of the lakes listed in PURA Section 38.004(b).

- For each utility that self-identified a line that did not meet vertical clearance requirements in an annual report filed in either Project 50596 or Project 51890, a declaration that each line identified in the annual report meets the NESC Standard.

Per Project 50596 and Project 51890 all lines are in compliance with PURA 38.004

- If a line over a lake listed in PURA 38.004(b) does not meet the NESC Standard:
  - The name of line;
  - The name of lake and the county or counties in which the lake is located;
  - A narrative description of actions the utility will take to bring the line into compliance with the NESC Standard; and
  - The data by when the line will be brought into compliance.

Cherokee County Electric Cooperative Association's  
House Bill 4150 Compliance Report

The following is a list of the crossings that did not comply with Rule 232 of the NESC in effect as of September 1, 2019

<b>Line ID</b>	<b>Lake</b>	<b>Counties</b>	<b>Action</b>	<b>Est. Data for Compliance</b>
PL.18658 FDR-0702	Lake Palestine	Smith	Replace 8 poles with taller poles	Q2 2022
PL.1942 FDR-0702	Lake Palestine	Smith	Replace 5 poles with taller poles	Q2 2022
PL.11349_001 FDR-1102	Lake Tyler	Smith	Replace 5 poles with taller poles	Q3 2022

Cherokee County Electric Cooperative Association's  
House Bill 4150 Compliance Report

**AFFIDAVIT**

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct and complete.

Chris Young  
Signature

Chris Young  
Printed Name

Engineer  
Job Title

Cherokee County Electric Cooperative Association  
Utility

Sworn and subscribed before me this 11<sup>th</sup> day of January, 2022.

Melissa Martin  
Notary Public in and For the State of Texas.

My commission expires on April 6<sup>th</sup> 2024.

